

April 25, 2007

DTR CONCRETE PRODUCTS, LLC
DUANE ROFFERS
W 361 COUNTY RD EE
DE PERE WI 54115

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: DTR CONCRETE PRODUCTS, LLC
Product Name: SEPTIC/SEPTIC/SEPTIC, SEPTIC/SEPTIC/PUMP OR HOLDING
Model Number(s): 1650 GALLON 3 COMPARTMENT SEPTIC/SEPTIC/PUMP or 2000 HOLDING
(45" L.L., 15.8/6.2/14.9 GAL/IN., 60" MAX. DEPTH OF BURY, 796 G.P.D. WHEN USED AS
A
SEPTIC/SEPTIC/SEPTIC TANK OR 474 G.P.D. WHEN USED AS A
SEPTIC/SEPTIC/PUMP TANK BASED ON A 3 YR. SERVICE INTERVAL FOR
RESIDENTIAL WASTEWATER)
Product File No: 20070139

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2012.

This approval supersedes the approval issued on December 8, 2011, under product file number 20060531.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060531.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.

- This product is approved to use the following:
 - Department approved plastic risers and covers installed as required by product approval for the plastic risers and covers with the first riser cast into cover at time of tank production.
 - Conduit hole cast in riser for electrical wiring.
 - Polylok IV High Pressure Pipe Boot Seal by Polylok.
 - Four inch cast iron or schedule 40 ABS or PVC elbow cast in end of cover to create an inlet through the cover when the tank is used as a holing tank.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov